

SIMPLIFIED TESTS CERTIFICATE

No. 09/996-3014-S

Bellaterra, 22th December 2009		Product:
PROYECTOS DE APLICACIÓN Y TÉCNICAS CONSTRUCTIVAS, S.L.		EPOMIT 200
C/ De la Riera, 15 08440 CARDEDEU		
ADHESIVES FOR CERAMIC TILES, UNE-EN 12004:2008		Class:
Initial Tests for CE Marking, Received Material: Reaction resin adhesive		R2
REQUESTED TESTS AND SUMMARY OF RESULTS:		
Test date: From 05/11/2009 to 18/12/2009.		
Dosage		19,6 Kg Comp. A : 0,4 Kg Comp. B
Determination of open time, UNE-EN 1346:2008	After 20'	≥ 0,5 N/mm²
Initial shear adhesion strength UNE-EN 12003:2009 7.3		≥ 2,0 N/mm²
Shear adhesion strength after water immersion UNE-EN 12003:2009 7.4		≥ 2,0 N/mm²
Shear adhesion strength after thermal shock UNE-EN 12003:2009 7.5		≥ 2,0 N/mm²
Determination of the slip, UNE-EN 1308:2008		≤ 0,5 mm

Responsible for Construction Mat.
LGAI TECHNOLOGICAL CENTER, S.A.

Technician Responsible
LGAI TECHNOLOGICAL CENTER, S.A.

The complete results are in the original test report at disposal of the client with n ° 09/996-3014

The results that are indicated, refer exclusively, to the sample, product or material delivered in the laboratory and tested in the conditions indicated in the procedure or procedures mentioned in this document. Only have legal validity the reports with original signatures or his collated copies in paper.

Applus+, guarantees that this work has been made in accordance with our Quality and Sustainability System, fulfilling the contractual conditions and legal norms.

Within our improvement program we would be grateful if you would send us any commentary that you consider oportune, to the person in charge who signs this document, or to the Quality Manager of Applus+, in the following e-mail address:
satisfaccion.cliente@appluscorp.com